



अधिशाली अभियन्ता खण्ड कार्यालय,

उ० प्र० जल निगम (ग्रामीण), जालौन

Email Add.- ceoraidiv@gmail.com, Ph. (O) 05162-258025

पत्रांक

2765

/

m-16

/ 62

दिनांक- 30/09/2026

PATH FINDERS,
INTERNATIONAL SCHOOL,
Jalaun Road,
Disst-Jalaun, Mob No-8604490448.

विषय:- जनपदीय जल परीक्षण प्रयोगशाला जालौन द्वारा पेयजल परीक्षण रिपोर्ट के सम्बन्ध में।

उपरोक्त विषयक PATH FINDERS, INTERNATIONAL SCHOOL, Jalaun Road, Disst-Jalaun, Mob No-8604490448. के पत्र सं० ए०एफ०आर०/2026 दिनांक 26.09.2026 के द्वारा पेयजल नमूने को एकत्र कर जनपदीय जल परीक्षण प्रयोगशाला में परीक्षण हेतु उपलब्ध कराया गया था, जिसके क्रम में जनपदीय जल परीक्षण प्रयोगशाला, जालौन द्वारा उक्त जल नमूने का परीक्षणोपरान्त NABL से Accredited प्रयोगशाला की जल परीक्षण रिपोर्ट संलग्न कर प्रेषित है।

संलग्नक:- उपरोक्तानुसार।

(ए०के० गुप्ता)
अधिशाली अभियन्ता

पृष्ठ संख्या एवं दिनांक यथोपरि:-

प्रतिलिपि:- निम्नलिखित को सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित है।

1-सम्बन्धित सहायक अभियन्ता/जूनियर इंजीनियर (प्रयोगशाला)।

अधिशाली अभियन्ता



Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
Oral, Jalaun



TC-13445

Analysis Water Test Report

ULR No.	TC-13445-2600000033F	Date - 29/09/2026
Customer Name	PATH FINDERS INTERNATIONAL SCHOOL	
Office Name and address	Jalaun road , orai	
Ref. Letter No. & date	AFF/2026 & 26-09-2026	

Basic details of sample

District	Jalaun	Block	Dakore
Gram Panchayat	Kukargaon	Village/ Mohalla	Kukargaon
Habitation		Location / Site name	Jalaun road, orai
latitude	26.04224	longitude	79.408205
Water Source	Bore-well	Sample Number	1
Quantity of sample	1	Date of sample collection	28/09/2026
Sample receiving date	28/09/2026	Name of sample collector	Mohini
Name of Sample depositor	Ramnaresh	Date of Analysis Completion	29/09/2026
Date of Analysis Start	28/09/2026	Sampling method	IS Method

Technical Data of Analysis

S. No.	ANALYSED PARAMETER	Units	OBSERVED VALUES	SPECIFIED VALUES AS Per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH	-	7.30	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity	NTU	0.90	1.0	5.0	IS 3025 (Part 10) : 2023 (Nephelometer method)
3	Chloride (as Cl)	mg/L	3.33	250	1000	IS 3025 (Part 32) : 2019 (Silver Nitrate)
4	Total Hardness (as CaCO ₃)	mg/L	62.67	200	600	IS 3025 (Part 21) : 2019 (EDTA)
5	Calcium as Ca	mg/L	12.90	75	200	IS 3025 (Part 40) : 2023 (EDTA)
6	Alkalinity (as Na ₂ CO ₃)	mg/L	233.33	200	600	IS 3025 (Part 23) : 2023 (Indicator method)
7	Magnesium (as Mg)	mg/L	11.94	30	100	IS 3025 (Part 46) : 2023
8	Fluoride (as F)	mg/L	0.500	1.0	1.5	APHA 24th Edition -4500-F Method D (SPANDS Method)
9	TDS	mg/L	134.00	500	2000	IS 3025 (Part 16) : 2023 (Gravimetric method)
10	Colour	Hazen	0.50	5HU	15HU	IS 3025 (Part 04):2021
11	Taste	-	Agreeable	Qualitative	-	IS 3025 (Part 08):2023
12	Odour	-	Agreeable	Qualitative	-	IS 3025 (Part 05) :2023

NOTE:

- 1- This certificate refers only to the particular sample(s) submitted for testing.
- 2- This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
- 3- The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- 4- Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Contaminated

Not Contaminated

Prepared by
(Kapil Kumar)

Technical Manager
District Water Analysis Laboratory
U.P.J.N., Jalaun

Authorized Signatory
(Manoj Kumar)

QUALITY MANAGER
District Water analysis Laboratory
U.P.J.N., Jalaun



Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural) Orai, Jalaun
Analysis Water Test Report

Report Number	Bacteriological Test/33/2026/2027	Date - 29/09/2026
Customer Name	PATH FINDERS INTERNATIONAL SCHOOL	
Office Name and address	Jalaun road , orai	
Ref. Letter No. & date	AFF/2026 & 26-09-2026	

Basic details of sample

District	Jalaun	Block	Dakore
Gram Panchayat	Kukargaon	Village/ Mohalla	Kukargaon
Habitat		Location / Site name	Jalaun road , orai
Latitude	26.042240	Longitude	79.408205
Water Source	Bore-well	Sample Number	1
Quantity of sample	1	Date of sample collection	28/09/2026
Sample receiving date	28 September, 2026	Name of sample collector	Mohini
Name of Sample depositor	Ramnaresh	Date of Analysis Completion	29/09/2026
Date of Analysis Start	28 September, 2026	Sampling method	IS Method

Technical Data of Analysis

S. No.	ANALYSED PARAMETER	OBSERVED VALUES	SPECIFIED VALUES AS Per IS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	pH	7.30	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Residual Chlorine (Mg/l)	0.00	0.2	1	IS 3025 (Part 26)
3	Total Coliform (CFU)	0.00	No relaxation	No relaxation	IS 10500:2012
4	E.Coli (CFU)	0.00	No relaxation	No relaxation	IS 10500:2012

NOTE:

- 1- This certificate refers only to the particular sample(s) submitted for testing.
- 2- This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
- 3- The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- 4- Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Contaminated

Not Contaminated

Authorized Signatory
QUALITY MANAGER
District Water analysis Laboratory
U.P.J.N. Jalaun

Brom